Guardian Fire Equipment, Inc.

3430 NW 38th St • Miami, Florida 33142

Phone: (305) 633-0361 • Fax: (305) 638-4632

Company:	
Project:	
Signature:	
Date:	

SPECIFICATIONS CHART

Project Information										Factory Information			
							Required Outlet (PSI)						
	Location	Model		INLET (PSI)		Flow	Static	Residual		EXPECTED			
Qty.	Tag	No.	Size	Static	Residual	GPM	Max.	Min.	Max.	Static	Residual	Flow	Type

"Type" Selection Procedure

1. Customer to complete "project information" section and return to Guardian Fire
   (Required outlet pressures must be in compliance with local authorities having jurisdiction in project location)
2. Guardian Fire to complete "Factory Information" section and return to customer for approval.

PRV10082

Note: Measured pressures may vary +/- 10% from expected